

SUPPLEMENTAL HEATING DEVICE AND WOOD/COAL BURNING STOVE REPORT

Coverage cannot be considered unless report is completed in its entirety.

Policy No: _____ Date of Insp.: _____

Applicant: _____ Inspected By: _____

Address: _____ Agent: _____

1. Attach required photos. See underwriting / page U11

2. Wood Stove Mfg. _____ **Model #** _____ **Age of Stove** _____

Installed by: _____ **Owner** _____ **Contractor (Name)** _____ **Date of Installation** _____

Wood Stove Construction Features: _____ **Cast Iron Fire Box** _____ **Steel Fire Box** _____ **Fan**

(Check Only Applicable Features): _____ **Fire Brick Lining** _____ **Sand at Bottom**

3. Vent System: a) _____ **Masonry *with* Tile Liner** _____ **Masonry *without* Tile Liner**
 b) _____ **UL Listed Metal Chimney** _____ **Single Wall Sheet Metal** _____ **Triple Wall Sheet Metal**
 c) _____ **Other** _____

Firewood has been seasoned? _____ **1 Year** _____ **6 months** _____ **Not at all**

How often is chimney cleaned and by what means? _____

	Yes	No*
4. Is stove free of cracks broken parts or repairs by welding?	___	___
5. Is stove located on non-combustible floor material? (Type of material _____)	___	___
6. Does floor protection extend at least 6" from sides and back, and 18" to the side where ashes are removed?	___	___
7. Is stove spaced at least 36" from any combustible material?	___	___
8. Is there at least 18" between top of stove pipe and ceiling or combustible side walls?	___	___
9. Does stove pipe fit snugly into thimble?	___	___
10. Is stove pipe routed so as not to pass through floors, closets, concealed space, or connected to chimney in attic?	___	___
11. Does stove have an automatic draft regulator or built in damper?	___	___
12. If not, does chimney have a damper located near stove?	___	___
13. Are any other stoves or furnaces vented to the same chimney?	___	___
14. If so, does it enter horizontally at a point higher than outlet of stove firebox?	___	___
15. Does chimney terminate 3' above roof penetration and 2' above any portion of the roof within 10'?	___	___
16. Is vent pipe or chimney free of creosote deposits?	___	___
17. Does vent system have spark arrestor?	___	___
18. Is woodburning stove vent system equipped with heat reclaiming unit or flue radiator?	___	___
19. If wall covering behind stove is metal or asbestos board, is it installed on one inch spaces to allow air movement behind same?	___	___

*Explain all "No": _____

Information Requested below must be provided:

Wall Covering Behind Stove:

- Solid Brick
- Face Brick (e.g. z-brick)
- Stove Board
- Interior Paneling
- Metal
- Other _____

Wall Construction:

- Solid Brick
- Wood Framed
- Concrete Block
- Other _____

Thimble Material:

- Clay
- Metal
- Other _____

Interior Pipe:

- Single Wall
- Double Wall
- Triple Wall

Location of Stove: _____ **Ex. Den in original mfg. home**
Ex. Den in stick built addition

Thimble width (Distance from edge of thimble to stove pipe): _____

Complete Diagram and include measurements _____ **Ex. A 48"**

